GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

RWS&S – Visakhapatnam District- 15 works pertaining to Narsipatnam Assembly Constituency in Visakhapatnam District with an amount of Rs.234.00 Lakhs (Rupees Two Crores Thirty Four Lakhs only)– Sanctioned under State plan - Administrative sanction -Accorded - Orders - Issued.

PANCHAYAT RAJ AND RURAL DEVELOPMENT (RWS.II) DEPARTMENT

G.O.RT.No. 531 Dated: 28-05-2016

O R D E R:

Keeping in view of the scarcity of drinking water in Narsipatnam Assembly Constituency in Visakhapatnam District, Government after careful examination of the matter hereby sanction certain works and also accord Administrative sanction to the Chief Engineer-I (Admn), Rural Water Supply and Sanitation Department, Hyderabad for an amount of Rs.234.00 Lakhs (Rupees Two Crores Thirty Four Lakhs only) respectively under State Plan, as a Special Case. The list of works are appended to this order as Annexure.

2. The Chief Engineer-I (Admn), Rural Water Supply and Sanitation Department, Hyderabad shall take necessary action in the matter.

3. This order is available on the internet and can be accessed at the address www. goir.ap.gov.in.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

Dr.K.S.JAWAHAR REDDY
PRINCIPAL SECRETARY TO GOVERNMENT

To
The Chief Engineer-I (Admn), Rural Water Supply and Sanitation Department,
SRTGN Bhavan, Errummunzil Colony, Hyderabad.
The Director of Treasuries and Accounts, Hyderabad.
The Director of Works and Accounts, A.P, Hyderabad
The Pay and Accounts Officer, A.P, Hyderabad
The Accountant General, AP, Hyderabad.
The Sr. Deputy Accountant General (LBAA), O/o. the A.G.,A.P., Hyderabad.

Copy to:
The District Collector, Visakhapatnam.
The OSD to M(PR&RWS)
The P.S. to Principal Secretary to Govt., RWS&S Department.
SF/SC.

//FORWARDED BY ORDER//

SECTION OFFICER

(PTO for Annexure)

Annexure to G.O.Rt. No.531, Dt:28.05.2016

WORKS SANCTIONED TO NARSIPATNAM CONSTITUENCY UNDER RWS STATE PLAN

(Rs.in Lakhs)

S NO	Name of the Mandal	Name of the Gram Panchayat	Name of the Habitation	Type of work	Population	Reasons for Proposal	Amount Sanctioned	Remarks
1	2	3	4	5	6	7	8	9
1	GOLUGONDA	Cheedigummala	Yerravaram	Augmentation to PWS Scheme	160	Existing 10 KL scheme is insufficient to meet the demand required. Therefore additional 20 kl OHSR and distribution in that village was proposed.	20.00	ST locality
2	GOLUGONDA	Cheedikada	Cheedikada SC Colony	Augmentation to PWS Scheme	130	Existing 20 KL scheme is insufficient to meet the demand required. Therefore additional 10 kl OHSR and distribution in that village was proposed.	15.00	ODF Village & ST,SC locality
3	GOLUGONDA	Kasimi	Kasimi	New MPWS	127	New scheme required for Kasimi village	15.00	ST locality
4	GOLUGONDA	Kasimi	Kothuru	New MPWS	78	New scheme required	15.00	plain locality
5	MAKAVARAPALEM	Pydipala	Ayyanna colony	Providing SVS Scheme Ayyanna colony	270	Village having a population of 270, Existing Bore wells - 2 , and households of 48 village having only source serving 20 Lpcd hence village must required 10 Kl ohsr and distribution net work to achieved 55 LPCD	13.00	
6	MAKAVARAPALEM	Settipalem	settipalem	Augmentation to PWS Scheme	1011	Village having a population of1011, Existing Bore wells - 12 , and 1 MPWS schemes with 10KL OHSR wih 3.00 mtrs Staging and house holds village is 180 having only source serving 12 Lpcd and water not serving into higher elevations hence village must required 40 Kl ohsr and distribution net work to achieved 55 LPCD	20.00	

7	MAKAVARAPALEM	papayyapalem	BUTCHANNAPALEM	Augmentation to PWS Scheme	410	Village having a population of 410, Existing Bore wells - 9 , and 1 MPWS schemes with 10KL GLSR and households village is 75 having only source serving 25 Lpcd and water not serving into higher elevations hence village must required 20 Kl ohsr and distribution net work to achieved 55 LPCD	15.00	
8	MAKAVARAPALEM	PP Agaraharam	PP Agaraharam	Augmentation to PWS Scheme	Benifited population 633	Village having a population of 633, Existing Bore wells - 12 , and 1 MPWS schemes with 10KL OHSR 3.00 mtrs staging and households village is 165 having only source serving 15Lpcd and water not serving into higher elevations hence village must required 20 Kl OHSR and distribution net work to achieved 55 LPCD	15.00	ODF Village
9	MAKAVARAPALEM	Narayanarajupeta	Narayanarajupeta	Augmentation to PWS Scheme	608	Village having a population of 608, Existing Bore wells - 5 , and 1 MPWS schemes with 10KL OHSR and households village is 135 having only source serving 30 Lpcd and water not serving into higher elevations hence village must required 20 Kl ohsr and distribution net work to achieved 55 LPCD	20.00	ODF Village
10	NARSIPATNAM	Darmasagaram	Duggada	Augmentation to PWS Scheme	758	Village having population of 758 and of 4 Hand Pumps. Village is located at higher elevation. Existing Bore well is yielding very low. Hence New source with Pump set and 20 KL OHSR is proposed. The population of village is 758.	15.00	

11	NATHAVARAM	R P Agraharam	chinna GOLUGONDA peta	Augmentation to MPWS Scheme	651	Existing 10 kl OHSR with 3 mts staging tank having insufficient distribution AND existing two public tap points and insufficient storage tank to village hence required new 20 KL Storage tank and distribution net work.	20.00	ODF Village
12	NATHAVARAM	Gummadigunda	SC Colony Gummadigunda	Augmentation to MPWS Scheme	326	village having Direct pumping with 2 tap points required Storage tank and distribution	15.00	SC locality
13	NATHAVARAM	Marripalm	Vennalapalem	Augmentation to PWS Scheme	436	Village having a population of 550, Existing Bore wells - 2 , and households of 135 village having only source existing 10 kl OHSR 3 mtrs stging serving 20 LPCD with 5 single tap only in the village hence village must required 20 Kl ohsr and distribution net work.	14.00	
14	NATHAVARAM	SB patnam	SB Patnam SC colony	providing storage tank at sc colony SB patanm	326	Existing Direct pumping scheme required storage facility benefitted sc population 302	12.00	SC locality
15	NATHAVARAM	Chrlopalem	Laxmipuram	Augmentation to PWS Scheme Laxmipuram	670	Existing 10 kl tank having insufficient distribution in the village hence required new extension of pipe line and storage insufficient to this village population hence required augmentation	10.00	
						TOTAL	**234.00**	

Dr.K.S.JAWAHAR REDDY
PRINCIPAL SECRETARY TO GOVERNMENT